



NOTES:

1. "NO PARKING-FIRE LANE" LETTER MARKINGS SHALL BE YELLOW.
2. LETTERS SHALL BE A MINIMUM OF 8" HIGH AND SPACED 8" FROM THE EDGE OF PAVEMENT.
3. LETTER MARKING SHALL BE PLACED EVERY 40' AND AT EVERY FIRE HYDRANT.
4. SOLID 4" WIDE YELLOW LINE SHALL BE PLACED 2" FROM THE EDGE OF PAVEMENT.

TOWN OF APEX
STANDARDS

EFFECTIVE: DECEMBER 21, 2010

FIRE LANE PAVEMENT MARKING

STD. NO.

300.24

SHEET 1 OF 1