



IN-LINE WYE FITTING OR APPROVED TAPPING SADDLE PROVIDED AT TOP QUARTER OF THE MAIN

IN-LINE WYE REQUIRED FOR SANITARY SEWER SERVICES INSTALLED WITH NEW CONSTRUCTION WHEN PARCEL AND SERVICE LOCATIONS ARE KNOWN AND IDENTIFIED ON APPROVED PLANS

**DEPTH ≤ 16 FEET - CLASS "A" BEDDING**

- UNDERCUT TRENCH BOTTOM 6 INCHES MINIMUM BELOW PIPE
- FILL PIPE TO SPRING LINE WITH NO. 57 OR 67 STONE

**DEPTH > 16 FEET - CLASS "B" BEDDING**

- UNDERCUT TRENCH BOTTOM 6 INCHES MINIMUM BELOW PIPE
- FILL TO 6 INCHES ABOVE PIPE WITH NO. 57 OR 67 STONE

INSTALLATIONS THAT EXCEED 20 FEET DEPTH SHALL BE DIP

TOWN OF APEX  
STANDARDS

EFFECTIVE: JULY 21, 2015

**SANITARY SEWER TAP & SERVICE**

STD. NO.

**700.02**

SHEET 1 OF 1